



**BOLTS AS PER DIN 933,  
 CARBON STEEL GRADE 4.8/6.8/8.8  
 WITH DACROMET  
 THICKNESS 8-10UM/HOT  
 DIP GALVANIZATION  
 30-40UM/STAINLESS STEEL  
 A2/A4 OR AS PER CLIENT REQUIREMENT**

**WASHER AS PER DIN125,  
 CARBON STEEL GRADE  
 4.8/6.8/8.8 WITH DACROMET  
 THICKNESS 8-10UM/HOT  
 DIP GALVANIZATION  
 30-40UM/STAINLESS STEEL  
 A2/A4 OR AS PER CLIENT  
 REQUIREMENT**

**GASKET  
 EPDM AS PER EN681-1  
 OR NBR AS PER EN682**

**BODY  
 DUCTILE IRON EN GJS450-10 AS PER  
 EN1563 OR OTHERS AS PER CLIENT  
 REQUIREMENT**

**PRECAUTIONS**

- 1, Suitable for AC (Asbestos Cement) pipes.
- 2, Sealing is achieved by compressing the EPDM gasket supported by PTFE against the bottom of the isolation valve. The opening and closing of the branch pipeline are controlled by isolation valve.
- 3, Medium conveyed can be water, oil or gas.

UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS SURFACE FINISH: TOLERANCES: LINEAR: LINEAR: ANGULAR:		FINISH:	DEBUR AND BREAK SHARP EDGES	DO NOT SCALE DRAWING	REVISION
NAME	SIGNATURE	DATE		TITLE: <b>SADDLE CLAMP FOR AC PIPE (ASBESTOS CEMENT PIPE )</b>	
DRAWN				MANUFACTURER QINGDAO JUDBERD MACHINERY CO LTD	
CHK'D				SCALE:	
APPV'D				SHEET 1 OF 1	
MFG					
Q.A			MATERIAL:		
			WEIGHT:		

